

IEEE Guide For Partial Discharge Testing Of Shielded Power Updated Version

High Voltage Test Techniques Partial Discharge Measurements

In the realm of electrical engineering and power systems, ensuring the integrity and reliability of high voltage equipment is paramount. Among the various diagnostic methods, **partial discharge (PD) measurements** have become a cornerstone technique for assessing the health of high voltage apparatus such as transformers, cables, GIS (Gas Insulated Switchgear), and insulators. This article delves into the intricacies of high voltage test techniques centered around partial discharge measurements, exploring their principles, methodologies, and significance in preventive maintenance and asset management.

Understanding Partial Discharges and Their Significance

What Are Partial Discharges?

Partial discharges are localized electrical discharges that occur within or on the surface of insulation systems when the electric field exceeds a certain threshold but is insufficient to cause complete dielectric breakdown. These discharges are typically tiny sparks or plasma formations that do not bridge the entire insulation gap, hence the term "partial."

Why Are Partial Discharges Important?

- **Indicator of Insulation Degradation:** PD activity often signifies the inception or progression of insulation deterioration.
- **Predictive Maintenance:** Monitoring PD levels allows for early detection of potential failures, facilitating timely interventions.
- **Extended Equipment Lifespan:** Identifying and mitigating PD sources can significantly prolong the service life of high voltage assets.
- **Compliance and Safety:** Ensuring PD levels are within acceptable limits is essential for meeting industry standards and preventing catastrophic failures.

Principles of Partial Discharge Measurement

Fundamentals of PD Detection

Partial discharges produce electromagnetic signals, acoustic emissions, and chemical changes that can be detected and analyzed. The most common approach involves measuring the electrical pulses associated with PD activity using specialized test equipment.

Types of Partial Discharges

- **Surface PD:** Occurs along the interface of different materials or on insulator surfaces.
- **Internal PD:** Takes place within the voids, cracks, or inclusions inside the insulation material.
- **Corona PD:** Happens around sharp or pointed conductors, often in gas-filled spaces.

High Voltage Test Techniques for Partial Discharge Measurements

Offline Partial Discharge Testing

Offline PD testing involves applying high voltage to equipment that is disconnected from the live system. This method is typically performed during factory acceptance or routine maintenance.

Procedure

- Connect the test setup with the equipment under test (EUT) using appropriate coupling devices.
- Gradually increase the test voltage while monitoring PD activity.
- Record PD signals at various voltage levels to determine inception and extinction voltages.
- Analyze the data to assess the insulation condition.

Advantages and Limitations

- **Advantages:** Controlled environment, high sensitivity, and detailed analysis.
- **Limitations:** Equipment must be offline, which may not be feasible for all assets.

Online Partial Discharge Testing

Online PD testing is performed while the equipment is energized and connected to the operational system, providing real-time condition monitoring.

Procedure

- Install portable PD measurement devices or sensors on energized equipment.

- Use high-frequency current transformers (HFCT) or other coupling techniques to detect PD signals without disrupting operation.
- Continuously monitor PD activity during normal operation.
- Implement data analysis and trending to identify changes over time.

Advantages and Limitations

- **Advantages:** No downtime required, provides trending data for predictive maintenance.
- **Limitations:** Higher background noise, more complex signal analysis.

Measurement Techniques and Equipment

Electromagnetic Detection Methods

- **HFCT Sensors:** Detect high-frequency signals generated by PD activity, often used in online testing.
- **Radio Interference (RIV) Method:** Measures the radio frequency emissions from PD sources.

Acoustic Emission Testing

Utilizes piezoelectric sensors to detect acoustic signals produced by PD discharges, particularly useful for surface PD detection.

Chemical Methods

Analyzes chemical by-products of PD (like ozone or nitric acid) in insulating oil or gas, providing indirect evidence of PD activity.

Data Analysis and Interpretation

PD Pattern Recognition

Analyzing the shape, amplitude, and frequency of PD pulses helps differentiate between various defect types and severity levels.

Key Parameters in PD Measurement

- **PD Inception Voltage:** The voltage at which PD activity first appears.

- **PD Extinction Voltage:** The voltage below which PD activity ceases.
- **PD Magnitude:** The measure of discharge amplitude, indicating defect severity.
- **PD Frequency:** The rate of PD pulses per unit time, which can suggest defect growth.

Trend Analysis and Monitoring

Long-term PD monitoring enables tracking of discharge activity, helping predict insulation failure and plan maintenance schedules effectively.

Standards and Best Practices

Relevant Industry Standards

- IEEE 400 Series (e.g., IEEE 400.2, IEEE 400.3): Guidelines for PD testing and measurement.
- IEC 60270: Standard for measuring partial discharges using high-frequency current transformers.
- IEC 60076-3: Power transformer standards including PD testing procedures.

Best Practices for Accurate PD Measurements

- Ensure proper sensor coupling and grounding.
- Calibrate measurement instruments regularly.
- Perform measurements under stable environmental conditions.
- Run multiple tests to confirm consistency.
- Correlate PD data with other diagnostic methods such as insulation resistance or tan delta testing.

Challenges and Future Trends

Current Challenges

- Background noise interference, especially in online testing.
- Differentiating between harmless and harmful PD sources.
- Establishing universal acceptance criteria for PD levels.

Emerging Technologies

- Advanced signal processing and AI-driven pattern recognition for defect classification.
- Wireless sensor networks for continuous monitoring.
- Integration of PD measurement data into asset management systems for predictive analytics.

Conclusion

High voltage test techniques partial discharge measurements are vital tools in the proactive maintenance and assessment of high voltage equipment. By accurately detecting and analyzing PD activity, engineers can identify early signs of insulation deterioration, prevent unexpected failures, and extend the operational life of critical assets. While offline tests provide detailed insights in controlled environments, online PD monitoring offers real-time health status, enabling more dynamic maintenance strategies. As technological advancements continue to evolve, the integration of sophisticated sensors, data analytics, and machine learning will further enhance the effectiveness and reliability of PD diagnostics, ensuring safer and more reliable power systems worldwide.

High Voltage Test Techniques: Partial Discharge Measurements

Introduction

In the realm of high voltage engineering, ensuring the reliability and longevity of electrical insulation systems is paramount. Among various diagnostic tools and test techniques, partial discharge (PD) measurements have established themselves as a critical method for assessing the integrity of high voltage equipment. This investigative article delves into the principles, methodologies, and advancements associated with partial discharge measurements, emphasizing their role in high voltage testing practices. By exploring the underlying physics, measurement techniques, interpretation strategies, and recent technological developments, this review aims to provide a comprehensive understanding of how PD measurements serve as a vital diagnostic tool in high voltage applications.

Understanding Partial Discharges in High Voltage Systems

What Are Partial Discharges?

Partial discharges are localized electrical discharges that occur within the insulation system of high voltage equipment when the electric field exceeds a certain threshold, but the voltage is insufficient to cause complete insulation breakdown. These discharges typically take place in voids, cracks, or inclusions within solid insulators, or in gas-filled cavities in liquid or solid dielectric materials.

Unlike complete breakdowns, which lead to catastrophic failure, partial discharges are often subtle and can persist over extended periods, gradually degrading insulation performance. Their presence and magnitude serve as early indicators of insulation deterioration, making PD measurements

invaluable for predictive maintenance and condition assessment.

Physical Phenomena Behind Partial Discharges

Partial discharges originate from localized ionization phenomena. When an electric field concentrates within voids or defects, it can ionize the gas or dielectric medium in that region. This ionization results in a small, transient current – the partial discharge. The discharge produces electromagnetic emissions, acoustic signals, and chemical by-products, all of which can be detected and analyzed.

The key factors influencing PD activity include:

- Void size and shape: Larger voids tend to produce more significant discharges.
- Material properties: Dielectric strength, permittivity, and thermal conductivity affect PD susceptibility.
- Voltage level and waveform: Higher voltages or specific waveforms can intensify PD activity.
- Environmental conditions: Moisture, contamination, and temperature influence PD behavior.

Principles of Partial Discharge Measurement

Fundamental Concepts

Partial discharge measurement involves detecting, recording, and analyzing the electrical signals generated during PD activity. The primary goal is to quantify the PD magnitude and characteristics to infer the health of the insulation system.

Key parameters include:

- Discharge magnitude: Usually expressed in picoCoulombs (pC) based on the charge transferred.
- Discharge inception voltage (PDIV): The minimum voltage at which PD occurs.
- Discharge extinction voltage (PDEV): The voltage level at which PD ceases.
- Repetition rate: The frequency of PD occurrences.
- Waveform shape and spectral content: Used for classification and diagnostic interpretation.

Measurement Techniques Overview

PD measurement techniques generally fall into two categories:

- Electrical methods: Detect PD signals via coupling devices (e.g., high-frequency current transformers, coupling capacitors).
- Acoustic/Ultrasound methods: Capture acoustic emissions generated by PD.
- Optical methods: Use of photomultiplier tubes or cameras to detect light emissions.
- Chemical analysis: Detect chemical by-products indicative of insulation degradation.

This review concentrates on electrical PD measurements, which are most widely used in high voltage testing.

High Voltage Test Techniques for Partial Discharge Measurement

Test Setups and Instrumentation

Effective partial discharge testing requires specialized equipment and carefully designed setups to ensure accurate detection and analysis.

Key components include:

- High Voltage Source: Capable of providing controlled AC, DC, or impulse voltages up to the test voltage level.
- Coupling Devices: Such as high-frequency current transformers (HFCT), coupling capacitors, or bushing tap connectors, to extract PD signals without disturbing the system.
- Measurement Instruments: Ultra-wideband oscilloscopes or PD analyzers with high sampling rates (often in the gigahertz range).
- Filtering and Shielding: To minimize noise and electromagnetic interference.
- Grounding and Safety: Proper grounding techniques and safety protocols are essential due to high voltages involved.

Typical test configurations include:

- Direct measurement setup: PD sensors connected directly to the equipment under test.
- Indirect measurement setup: Using external sensors with coupling capacitors or transformers.
- On-line testing: Continuous monitoring during operation.
- Off-line testing: Controlled laboratory or substation testing.

Measurement Procedures

The measurement process generally involves the following steps:

- Applying a prescribed voltage (AC, DC, or impulse) to the equipment.
- Monitoring the PD signals over a specified voltage range.
- Recording PD activity, including charge, phase position, and waveform shape.
- Identifying PD inception and extinction voltages.
- Analyzing the spectral content for diagnostic purposes.

Analysis and Interpretation of Partial Discharge Data

Quantitative Analysis

Quantitative PD assessment involves measuring the charge per discharge, typically in picoCoulombs, which correlates with defect size and severity. Consistent PD activity at low levels may indicate incipient defects, while high PD levels suggest significant insulation deterioration.

Key metrics include:

- PD magnitude distribution: Histogram of discharge sizes.
- PD pattern over voltage ramp: To determine PD inception voltage.
- Repetition rate and pulse density: To evaluate defect activity.

Qualitative Analysis

Waveform shape and spectral analysis help classify PD types:

- Internal discharges: Usually produce narrow, consistent waveforms.
- Surface discharges: Often show irregular, fragmented signals.
- Corona discharges: Characterized by repetitive, high-frequency signals.

Spectral analysis (FFT) can identify characteristic frequencies associated with specific defect types or environmental influences.

Diagnostic Criteria and Standards

Standards such as IEC 60270 provide guidelines for PD measurement and interpretation. Key criteria include:

- PD inception voltage relative to operating voltage.
- PD magnitude thresholds indicating acceptable or critical conditions.

- Pattern recognition for defect classification.
- Trend analysis over time for condition monitoring.

Advancements and Challenges in Partial Discharge Testing

Recent Technological Developments

- Digital Signal Processing (DSP): Enhanced noise filtering and pattern recognition.
- Wideband Sensors: Broader frequency response for improved sensitivity.
- Automated Data Analysis: Machine learning algorithms for defect classification.
- On-line Monitoring Systems: Continuous PD monitoring with real-time alerts.
- Integrated Testing Platforms: Combining PD measurements with other diagnostic methods like thermography or ultrasound.

Challenges and Limitations

Despite technological progress, PD testing faces several challenges:

- Noise and Interference: External electromagnetic noise complicates signal clarity.
- Complex Signal Interpretation: Differentiating between benign and critical PD activity requires expertise.
- Standardization and Calibration: Variability among equipment and sensors affects measurement consistency.
- Detection Limits: Very small or transient discharges may escape detection.
- Environmental Factors: Moisture, contamination, and temperature influence PD behavior and measurement accuracy.

Conclusion and Future Directions

Partial discharge measurements remain a cornerstone of high voltage testing and diagnostics, providing early warnings of insulation degradation and preventing catastrophic failures. As technology advances, the integration of digital signal processing, machine learning, and real-time monitoring systems promises to enhance the sensitivity, accuracy, and interpretability of PD data.

Future research avenues include developing more robust sensors resistant to environmental influences, refining diagnostic algorithms for automated defect classification, and establishing standardized protocols for on-line PD monitoring. Addressing current limitations will further solidify PD measurements as an indispensable tool in high voltage asset management, ensuring the safety, reliability, and efficiency of electrical power systems worldwide.

References

(Note: In an actual publication, references to standards like IEC 60270, recent journal articles, and technical reports would be included here.)

Question What is the primary purpose of partial discharge measurements in high voltage testing? The primary purpose is to detect and evaluate insulation defects or weaknesses within high voltage equipment, ensuring reliability and preventing catastrophic failures. Which partial discharge measurement techniques are most commonly used in high voltage testing? Common techniques include pulse method, phase-resolved partial discharge (PRPD) analysis, ultra-high frequency (UHF) measurement, and acoustic emission methods. How does partial discharge measurement help in assessing the insulation condition of high voltage equipment? It quantifies the presence, magnitude, and pattern of discharges, providing insights into insulation integrity, defect type, and severity, which aids in maintenance decisions. What are the key challenges associated with partial discharge measurements in high voltage tests? Challenges include electromagnetic interference, signal attenuation, equipment calibration, and distinguishing between genuine discharges and noise or external disturbances. How does frequency selection impact partial discharge testing in high voltage applications? Frequency affects the sensitivity and resolution of measurements; higher frequencies can detect smaller discharges and localized defects, but may also be more susceptible to noise, requiring careful selection based on the application. What role does phase-resolved partial discharge (PRPD) analysis play in high voltage testing? PRPD analysis provides a graphical representation of discharge activity relative to the AC cycle phase, helping identify defect types and their locations based on discharge patterns. What advancements are shaping the future of partial discharge measurement techniques? Emerging advancements include the use of machine learning for pattern recognition, UHF and broadband sensors for more accurate detection, and integrated online monitoring systems for continuous insulation health assessment.

Related keywords: high voltage testing, partial discharge detection, insulation testing, PD measurement methods, dielectric testing, high voltage equipment testing, partial discharge analysis, insulation diagnostics, PD measurement equipment, high voltage testing techniques

High Voltage Test And Measuring Techniques

high voltage test and measuring techniques are essential components in the electrical engineering industry, ensuring the safety, reliability, and durability of high voltage equipment and systems. These techniques are vital for diagnosing potential issues before they lead to catastrophic failures, thereby protecting personnel, equipment, and the environment. As electrical infrastructure grows increasingly complex, understanding the methods and best practices for high voltage testing

and measurement becomes vital for engineers, technicians, and industry professionals. This comprehensive guide explores the fundamentals, types, equipment, procedures, and safety considerations involved in high voltage testing and measuring techniques, providing valuable insights for those involved in the maintenance, design, and certification of high voltage systems.

Understanding High Voltage Test and Measuring Techniques

High voltage testing involves applying voltages higher than the operational voltage to electrical equipment and components to verify their dielectric properties and integrity. Measurement techniques are used concurrently to assess the equipment's ability to withstand these stresses, detect weaknesses, and ensure compliance with safety standards.

The primary goal of high voltage testing is to identify manufacturing defects, aging effects, or operational issues that could compromise performance or safety. Accurate measurement techniques are crucial for interpreting test results, determining whether equipment passes or fails, and ensuring consistent quality control.

Types of High Voltage Tests

High voltage tests can be broadly categorized based on their purpose, the nature of the test, and the equipment involved. Here are the most common types:

1. Dielectric Withstand Test (Dielectric Test)

- Also known as the withstand test.
- Purpose: To verify the dielectric strength of insulation.
- Procedure: Applying a high voltage (typically 1.5 to 2 times the rated voltage) for a specified duration.
- Key Point: Ensures the insulation can withstand operational stresses and transient overvoltages.

2. Insulation Resistance Test

- Purpose: To measure the resistance of insulation material.
- Procedure: Applying a low voltage (usually 500V to 1000V) and measuring resistance.
- Key Point: Indicates the general health of insulation; a decreasing resistance suggests deterioration.

3. Partial Discharge Test

- Purpose: To detect small electrical discharges within insulation.
- Procedure: Using specialized sensors and equipment to monitor partial discharges.
- Key Point: Early detection of insulation defects to prevent failure.

4. Power Frequency Voltage Test

- Purpose: To verify equipment can withstand operational voltage levels.
- Procedure: Applying voltage at the system's power frequency (50Hz or 60Hz) for a specific period.
- Key Point: Used for transformer and cable testing.

5. Very High Voltage (VHV) Testing

- Purpose: For specialized equipment requiring extremely high voltages.
- Procedure: Applying voltages in the megavolt range.
- Key Point: Mainly used in research or for testing very large equipment.

High Voltage Measuring Techniques

Accurate measurement is fundamental to high voltage testing. Several specialized techniques and instruments are employed to ensure precise and safe measurements:

1. Voltage Dividers

- Function: To step down high voltages to measurable levels.
- Types:
 - Resistive Dividers
 - Capacitive Dividers
- Application: Used in conjunction with voltmeters or oscilloscopes to measure high voltages indirectly.

2. High Voltage Probes

- Function: To connect measurement instruments safely to high voltage points.
- Types:
 - Resistive Probes
 - Capacitive Probes

- Features: Designed with high insulation resistance and minimal loading effects.

3. Digital Phosphor Oscilloscopes (DPOs)

- Utility: To visualize high voltage waveforms during testing.
- Benefit: Enables detailed analysis of transient phenomena like partial discharges.

4. High Voltage Test Instruments

- Examples:
 - High Voltage Test Sets
 - Megohmmeters
 - Partial Discharge Detectors
- Features: Built to withstand and accurately measure high voltage levels.

5. Measurement Techniques for Safety and Accuracy

- Use of shielded cables and proper grounding.
- Calibration of measurement instruments regularly.
- Implementing differential measurement techniques to reduce noise.
- Employing insulation monitoring devices to prevent accidental discharges.

High Voltage Testing Equipment

A variety of specialized equipment is used in high voltage testing to generate, apply, and measure high voltages safely and accurately:

1. High Voltage Generators

- Types:
 - Resonant Transformers
 - Voltage Multipliers
 - Power Amplifiers
- Purpose: To generate the required test voltages.

2. Test Cells and Fixtures

- Designed to hold the device under test securely.
- Made with insulating materials to prevent leakage currents.

3. Measurement and Control Devices

- Voltmeters and ammeters capable of high voltage measurements.
- Data acquisition systems for recording test data.
- Safety interlocks and emergency shut-off controls.

4. Partial Discharge Detectors

- Devices that detect and analyze partial discharges within insulation.
- Used to assess insulation integrity during testing.

Best Practices in High Voltage Testing and Measurement

To ensure safety, accuracy, and reliability during high voltage testing, the following best practices should be adhered to:

Safety Precautions

- Always wear appropriate personal protective equipment (PPE).
- Use insulated tools and equipment rated for the test voltage.
- Establish a designated safety zone around testing areas.
- Ensure proper grounding and shielding of all measurement devices.
- Implement lockout/tagout procedures to prevent accidental energization.

Preparation and Planning

- Inspect all equipment and test setups before testing.
- Verify calibration status of all measurement instruments.
- Review the test procedures and safety protocols.
- Notify relevant personnel about scheduled tests.

Executing the Test

- Gradually increase voltage to the test level to monitor equipment response.
- Observe and record measurements carefully.
- Watch for abnormal readings or arcing.
- Maintain communication with team members during testing.

Post-Test Procedures

- Gradually reduce voltage and turn off equipment.
- Inspect the device under test for any damage.
- Analyze measurement data for signs of insulation deterioration.
- Document findings and report anomalies.

Applications of High Voltage Testing and Measuring Techniques

High voltage testing is applied across various sectors, including:

- Power Generation and Transmission: Ensuring transformers, insulators, and cables can withstand operational stresses.
- Manufacturing: Quality control of electrical components and equipment.
- Research and Development: Testing new materials and insulation systems.
- Maintenance and Inspection: Routine testing of existing infrastructure to prevent failures.
- Certification and Compliance: Verifying that equipment meets national and international standards like IEC, IEEE, and ANSI.

Standards and Regulations

Compliance with industry standards ensures safety and consistency in high voltage testing. Key standards include:

- IEC 60060: High-voltage test techniques.
- IEEE 400 series: Guide for diagnostic site testing of transmission facilities.
- ASTM Standards: For specialized testing procedures.
- Always adhere to local electrical safety regulations and guidelines.

Conclusion

High voltage test and measuring techniques are fundamental to maintaining the safety, reliability, and efficiency of electrical systems. Mastery of these techniques involves understanding various

testing methods, employing specialized equipment, and following strict safety protocols. As the demand for high voltage infrastructure continues to grow, advancements in measurement technology and testing procedures will further improve accuracy and safety. Whether in manufacturing, maintenance, or research, implementing best practices in high voltage testing ensures the longevity and safe operation of critical electrical assets.

By staying informed and adhering to industry standards, professionals can effectively utilize high voltage test and measuring techniques to safeguard their systems and personnel.

High Voltage Test and Measuring Techniques: Ensuring Safety and Reliability in Power Systems

Introduction

High voltage test and measuring techniques are fundamental to the operation, maintenance, and safety assurance of electrical power systems. As the backbone of modern infrastructure, high voltage equipment such as transformers, insulators, and switchgear must operate reliably under demanding conditions. Proper testing and measurement not only verify equipment integrity but also prevent catastrophic failures, reduce downtime, and ensure safety for personnel and the environment. This article explores the key principles, methods, and latest advancements in high voltage testing and measurement techniques, providing a comprehensive understanding for engineers, technicians, and industry stakeholders.

Understanding High Voltage Testing: An Essential Overview

High voltage testing involves applying voltages significantly above the normal operating levels to equipment or components to evaluate their dielectric strength, insulation integrity, and overall robustness. These tests are crucial in both manufacturing and maintenance phases, serving as quality assurance measures and diagnostic tools.

Why High Voltage Testing Is Necessary

- Verification of Insulation Quality: Ensures that insulation materials can withstand operational stresses.
- Detection of Manufacturing Defects: Identifies flaws such as voids, cracks, or impurities that could cause failures.
- Preventive Maintenance: Monitors aging effects and degradation over time.
- Compliance with Standards: Meets safety and performance standards set by organizations like IEEE, IEC, and ANSI.

Key Principles of High Voltage Testing

- Dielectric Strength: The maximum electric field a material can withstand without breakdown.
- Leakage Current: Small currents that flow through insulation; increasing leakage indicates deterioration.
- Partial Discharges: Small electrical sparks within insulation that can signify potential failure points.

Types of High Voltage Tests

High voltage testing can be broadly categorized into two types:

- Routine Tests

Performed on all equipment before installation to confirm basic integrity.

- Dielectric Withstand Test (Hi-pot Test): Applies high voltage between conductors and ground.
- Visual Inspection: Checks physical condition and markings.
- Insulation Resistance Test: Measures the resistance of insulation to leakage currents.

- Type Tests

Conducted during the design phase or after major repairs to validate design specifications.

- Lightning Impulse Test: Simulates lightning strikes to assess insulation's ability to withstand transient overvoltages.
- Switching Impulse Test: Evaluates insulation response to switching surges.
- Partial Discharge Test: Detects microscopic discharges within insulation.

High Voltage Testing Techniques and Equipment

Technicians and engineers employ a variety of specialized techniques and equipment to perform high voltage tests effectively and safely.

- AC High Voltage Testing

Methodology: Applies sinusoidal alternating voltage to the equipment until the desired test level is reached, then holds the voltage for a specified duration.

Equipment Used:

- High voltage generators (e.g., cascade transformers or Tesla coils)
- Voltage dividers and measurement bridges
- Electric field probes for partial discharge detection

Advantages:

- Mimics operational conditions closely
- Suitable for testing insulation strength under normal operating environment

Limitations:

- Longer test durations
- Potential for equipment damage if not carefully controlled

- DC High Voltage Testing

Methodology: Uses direct current to test insulation, often for dielectric strength measurements.

Equipment Used:

- High voltage DC power supplies
- Electrometers for leakage current measurement

Advantages:

- Faster testing process
- Less risk of dielectric recovery issues

Limitations:

- Not always representative of operational conditions where AC is predominant

- Partial Discharge Measurement Techniques

Partial discharges (PD) are small electrical sparks that occur within insulation under high voltage stress. Detecting and analyzing PD activity provides early warning of insulation deterioration.

Methods:

- Ultrahigh frequency (UHF) detection: Captures PD signals in the UHF spectrum.
- Electromagnetic coupling: Uses sensors attached to equipment to monitor PD activity.
- Acoustic emission: Detects ultrasonic waves emitted by PD events.

Significance:

- Enables predictive maintenance
- Helps pinpoint insulation weak spots before failure occurs

- Tan Delta (Dissipation Factor) Measurement

This technique assesses insulation quality by measuring the dielectric losses within the material.

- Method: An AC voltage is applied, and the phase shift between voltage and current is measured.

- Interpretation: Higher tan delta values indicate increased dielectric losses, signaling insulation degradation.

Measuring Techniques: Ensuring Accurate and Safe Data Collection

Accurate measurement is vital for assessing equipment integrity and making informed decisions. Several advanced techniques and devices are employed:

- Digital Insulation Resistance Testers

Modern digital megohmmeters or megohm testers provide quick, reliable measurements of insulation resistance, often with data logging capabilities.

- Features:
 - Multiple test voltages
 - Automated testing procedures
 - Data storage and analysis options
- High Voltage Dividers and Voltage Test Sets

Precise voltage measurement is critical during high voltage tests.

- Voltage Dividers: Reduce high voltage to measurable levels with high accuracy.
- Test Sets: Combine high voltage source and measurement instruments for synchronized operation.
- Data Acquisition and Monitoring Systems

Real-time monitoring systems with embedded sensors and software facilitate continuous assessment.

- Partial discharge monitors
- Tan delta measurement systems
- Environmental sensors for temperature and humidity

These systems enable early detection of insulation issues, minimizing unexpected failures.

Safety Considerations in High Voltage Testing

High voltage testing is inherently dangerous and demands rigorous safety protocols:

- Proper Grounding: Ensures that equipment and operators are protected from stray voltages.
- Personal Protective Equipment (PPE): Insulating gloves, dielectric boots, and eye protection are mandatory.
- Controlled Environment: Testing should occur in designated areas with restricted access.
- Emergency Procedures: Clear protocols must be established for handling accidents or equipment faults.
- Training: Only qualified personnel should operate high voltage testing equipment.

Advancements in High Voltage Testing Technologies

The field continues to evolve with innovations that improve safety, accuracy, and efficiency:

- Automation and Remote Monitoring: Enables tests to be conducted remotely, reducing personnel exposure.
- Artificial Intelligence (AI): Analyzes large datasets from partial discharge and Tan delta measurements to predict failures.
- Portable High Voltage Test Equipment: Facilitates on-site testing without the need for large, stationary systems.
- Enhanced Sensors: Development of highly sensitive PD and dielectric loss sensors for early fault detection.

Conclusion

High voltage test and measuring techniques are indispensable tools in the electrical power industry, underpinning the safety, reliability, and longevity of high voltage equipment. From traditional AC and DC testing methods to advanced partial discharge and Tan delta techniques, each approach offers unique insights into insulation integrity. As technology progresses, the integration of automation, real-time monitoring, and intelligent analysis promises to further enhance testing efficacy and safety standards. For engineers and technicians, mastering these techniques ensures that power systems operate efficiently and safely, safeguarding the infrastructure upon which our modern lives depend.

In summary, high voltage testing is a complex but essential discipline that combines theoretical principles with practical applications. Continuous advancements in measurement techniques and safety practices underscore the industry's commitment to improving power system reliability and protecting personnel and assets. As the demand for resilient electrical infrastructure grows, expertise in high voltage test and measuring techniques will remain a cornerstone of electrical engineering excellence.

Question What is the purpose of high voltage testing in electrical equipment? High voltage testing is performed to verify the insulation strength and integrity of electrical equipment, ensuring it can withstand operating voltages without failure or breakdown. Which are common techniques used for measuring high voltages? Common techniques include the use of voltage dividers, potential transformers, electrostatic voltmeters, and digital high voltage testers designed specifically for accurate measurement at high voltages. How does a voltage divider work in high voltage measurement? A voltage divider reduces high voltage to a lower, measurable level by using a series of resistors or capacitors, allowing standard measuring instruments to safely and accurately read the voltage. What safety precautions should be taken during high voltage testing? Safety precautions include wearing insulating gloves and boots, using insulated tools, maintaining safe

distances, ensuring proper grounding, and following standardized procedures to prevent electric shocks or arc flashes. What is the significance of partial discharge testing in high voltage measurements? Partial discharge testing detects and evaluates small electrical discharges within insulation systems, serving as an early indicator of insulation deterioration and preventing future failures. How is a digital high voltage tester different from traditional methods? Digital high voltage testers provide quick, accurate, and easy-to-read measurements, often with built-in safety features, whereas traditional methods may require more manual calculations and are more operator-dependent. What are the main types of high voltage test equipment used in industry? Main types include AC and DC hipot testers, partial discharge testers, high voltage dividers, and portable high voltage testers for field testing and maintenance. Why is calibration important in high voltage measurement techniques? Calibration ensures the accuracy and reliability of measurement instruments, preventing errors that could lead to improper assessments of equipment insulation and safety. What is the role of corona discharge detection in high voltage testing? Corona discharge detection helps identify localized insulation weaknesses or contamination, which can cause partial discharges and eventual insulation failure if not addressed. What advancements are being made in high voltage measuring techniques? Recent advancements include non-invasive measurement methods, digital signal processing, improved sensor technologies, and remote testing capabilities to enhance accuracy, safety, and ease of use.

Related keywords: High voltage testing, insulation resistance measurement, dielectric withstand test, partial discharge testing, voltage divider, surge generator, testing equipment, electrical safety testing, test procedures, measurement accuracy

Read the full article online: [High Voltage Test And Measuring Techniques](#)

IEEE C57.12.90-1993

IEEE C57.12.90-1993: An In-Depth Guide to the Standard for Power Transformers

Understanding the IEEE C57.12.90-1993 standard is essential for professionals involved in the design, manufacturing, testing, and maintenance of power transformers. This standard provides comprehensive guidelines that ensure the safety, reliability, and efficiency of transformers used in electrical power systems. In this article, we will explore the scope, key provisions, testing procedures, and the importance of IEEE C57.12.90-1993, offering a detailed overview suitable for engineers, technicians, and industry stakeholders.

Overview of IEEE C57.12.90-1993

What Is IEEE C57 12 90 1993?

IEEE C57 12 90 1993 is a standard developed by the Institute of Electrical and Electronics Engineers (IEEE) that specifies the requirements for testing power transformers, specifically focusing on the dielectric properties and insulation performance. It aims to standardize testing procedures to assess the condition and reliability of transformers, ensuring they meet safety and performance criteria before deployment and during maintenance.

Historical Context and Revisions

Originally issued in 1993, this standard has undergone revisions to incorporate technological advancements and evolving industry practices. Its primary purpose is to harmonize testing protocols, improve transformer longevity, and reduce failures related to insulation degradation.

Scope and Applications of IEEE C57 12 90 1993

Types of Transformers Covered

The standard applies to:

- Distribution transformers
- Power transformers
- Special-purpose transformers used in various electrical applications

Testing Focus Areas

It emphasizes:

- Dielectric testing to evaluate insulation integrity
- Assessment of moisture content within insulation systems
- Detection of potential insulation defects
- Verification of transformer performance before and after installation

Use Cases

This standard is utilized during:

- Manufacturing quality control

- Pre-commissioning testing
- Routine maintenance and diagnostics
- Condition monitoring during transformer service life

Key Provisions of IEEE C57 12 90 1993

Testing Procedures

The standard outlines specific procedures for various tests, including:

- Power frequency dielectric tests
- Applied voltage tests
- Partial discharge measurements
- Moisture content assessment

Dielectric Testing Details

The dielectric test involves applying a specified voltage to the transformer insulation system and measuring its response. It ensures that:

- The insulation can withstand operational voltages
- No significant partial discharges are present, indicating insulation integrity
- Moisture levels are within acceptable limits to prevent insulation failure

Moisture Measurement and Control

Moisture within transformer insulation can significantly impair dielectric strength. The standard recommends:

- Using moisture meters to quantify moisture content
- Implementing drying procedures if moisture exceeds limits
- Regular monitoring during operation

Acceptance Criteria

Transformers must meet specific dielectric strength thresholds and partial discharge levels to pass testing, ensuring they are fit for service.

Testing Equipment and Techniques

Dielectric Testing Equipment

Reliable testing requires specialized equipment such as:

- High-voltage AC testers
- Partial discharge measurement devices
- Moisture meters tailored for transformer insulation

Testing Environment

Tests should be conducted under controlled conditions:

- Ambient temperature within specified limits
- Proper grounding and safety measures
- Calibration of testing instruments prior to use

Test Execution and Data Recording

Accurate documentation is crucial, including:

- Voltage levels applied
- Duration of tests
- Partial discharge levels observed
- Moisture readings

Importance and Benefits of IEEE C57 12 90 1993

Ensuring Transformer Reliability

Adherence to this standard guarantees that transformers are capable of withstanding operational stresses and environmental conditions, reducing unexpected failures.

Enhancing Safety

Proper testing as per IEEE C57 12 90 1993 minimizes electrical hazards, protecting personnel and equipment.

Facilitating Maintenance and Lifecycle Management

Regular testing against standard benchmarks helps in early detection of insulation degradation, enabling proactive maintenance and extending transformer lifespan.

Compliance and Industry Best Practices

Following recognized standards ensures compliance with regulatory requirements and aligns with industry best practices, fostering trust among clients and stakeholders.

Challenges and Considerations in Implementing IEEE C57.12.90-1993

Technical Expertise

Effective testing requires skilled personnel familiar with high-voltage equipment and diagnostic techniques.

Equipment Calibration and Maintenance

Ensuring testing devices are properly calibrated is vital for accurate results.

Environmental Factors

Ambient conditions can influence test outcomes, necessitating controlled environments or correction factors.

Cost Implications

High-quality testing equipment and skilled labor involve costs, which must be balanced against the benefits of reliable transformer operation.

Recent Developments and Future Trends

Advancements in Diagnostic Technologies

Emerging techniques such as online partial discharge monitoring and advanced moisture analysis tools are enhancing transformer diagnostics.

Integration with Condition Monitoring Systems

Modern transformers increasingly incorporate sensors and data analytics, aligning with standards

like IEEE C57.12.90-1993 to facilitate real-time health assessments.

Standard Revisions and Updates

Ongoing updates to IEEE standards aim to incorporate new technologies and improve testing precision and safety.

Conclusion

IEEE C57.12.90-1993 plays a pivotal role in ensuring the safety, reliability, and longevity of power transformers. By standardizing testing procedures for dielectric strength, moisture content, and insulation integrity, it helps industry professionals maintain high-quality electrical infrastructure. Proper implementation of this standard not only mitigates risks but also enhances operational efficiency and supports the sustainable growth of electrical power systems. Staying abreast of revisions and technological advancements related to IEEE C57.12.90-1993 is essential for professionals committed to excellence in transformer management and electrical safety.

IEEE C57.12.90-1993: An In-Depth Exploration of the Standard for Electrical Power Equipment Testing and Evaluation

Introduction

IEEE C57.12.90-1993 is a pivotal standard within the realm of electrical engineering, specifically focusing on the testing and evaluation procedures for electrical power equipment such as transformers, circuit breakers, and other high-voltage apparatus. Developed by the Institute of Electrical and Electronics Engineers (IEEE), this standard has served as a cornerstone in ensuring the reliability, safety, and performance consistency of electrical equipment used across power generation, transmission, and distribution systems. As technology advances and the demand for robust electrical infrastructure grows, understanding the scope, application, and significance of IEEE C57.12.90-1993 becomes essential for engineers, manufacturers, and utility operators alike.

Origins and Background of IEEE C57.12.90-1993

Historical Context and Development

The IEEE C57 series has long been recognized as a comprehensive set of standards addressing various aspects of power transformers and associated equipment. The 1993 revision, specifically C57.12.90, was developed to establish uniform testing procedures that facilitate the consistent evaluation of electrical power equipment. Prior to its publication, testing practices often varied significantly among manufacturers and utilities, leading to discrepancies in equipment assessment and potential reliability issues.

The standard was formulated through collaborative efforts by industry experts, incorporating advances in testing technology and lessons learned from operational experiences. Its goal was to provide a detailed, repeatable methodology that could be universally applied, thereby fostering confidence in the quality and performance of electrical components.

Scope and Purpose

IEEE C57.12.90-1993 primarily addresses the procedures for testing and evaluating the dielectric and mechanical properties of electrical power equipment, with a focus on:

- Transformers (including liquid-immersed and dry types)
- Instrument transformers
- Switchgear and circuit breakers

The document aims to:

- Define standardized testing methods
- Establish criteria for acceptance or rejection
- Provide guidance for interpreting test results
- Facilitate comparison across different manufacturers and models

This standardization is crucial for ensuring that equipment meets specified performance levels, minimizes failures, and aligns with safety regulations.

Core Components and Structure of IEEE C57.12.90-1993

Testing Procedures Covered

The standard delineates a comprehensive suite of tests, categorized broadly into dielectric tests, mechanical tests, and routine versus type tests.

- Dielectric Tests

- Power Frequency Tests: Assess the insulation strength by applying voltage levels at power frequency (typically 60 Hz).
- Impulse Tests: Simulate lightning strikes or switching surges to evaluate insulation resilience.
- Partial Discharge Tests: Detect localized dielectric breakdowns that could lead to failure.

- Tan Delta Tests: Measure dielectric losses, indicating insulation condition.
- Mechanical Tests
 - Bending and Shock Tests: Determine mechanical robustness under handling or transportation stresses.
 - Pressure Tests: Verify the integrity of sealed or enclosed components.
- Routine and Type Tests
 - Routine tests are performed on each unit to ensure compliance with specifications.
 - Type tests are conducted on representative units to validate design features and manufacturing consistency.

Testing Conditions and Parameters

The standard specifies detailed conditions under which tests must be performed, including:

- Temperature and humidity levels
- Test voltages and durations
- Equipment calibration procedures
- Safety protocols

The emphasis on controlled conditions ensures that test results are accurate, comparable, and meaningful.

Significance and Applications of IEEE C57.12.90-1993

Ensuring Equipment Reliability

One of the fundamental objectives of IEEE C57.12.90-1993 is to promote equipment longevity and operational reliability. By adhering to rigorous testing protocols, manufacturers can identify potential weaknesses before deployment, and utilities can verify that purchased equipment meets industry standards.

Enhancing Safety Measures

Electrical failures pose safety hazards, including electrical shocks, fires, and system outages. The standardized testing procedures outlined in this document help detect insulation flaws, mechanical defects, or design shortcomings that could lead to hazardous situations.

Facilitating Industry Compliance and Quality Assurance

Manufacturers rely on this standard to demonstrate compliance during certification processes, while utilities use it as a benchmark for acceptance testing. Consistent testing practices foster industry-wide trust and facilitate international trade of electrical equipment.

Supporting Maintenance and Lifecycle Management

Regular testing based on the standard's guidelines can be integrated into preventive maintenance regimes, helping identify aging or deteriorating components early, thus reducing downtime and repair costs.

Impact on Manufacturing and Utility Operations

Standardization of Testing Protocols

IEEE C57.12.90-1993's detailed procedures have led to uniformity in how electrical equipment is tested worldwide. This reduces ambiguities and discrepancies, enabling manufacturers to design products that meet universally accepted benchmarks.

Quality Control and Certification

Adherence to the standard is often a prerequisite for obtaining certifications from regulatory bodies. It assures customers and stakeholders that the equipment has undergone rigorous verification, fostering confidence in performance and safety.

Troubleshooting and Diagnostic Processes

Utilities utilize the testing methodologies to diagnose issues during operation. For example, partial discharge measurements or dielectric loss assessments can identify early signs of insulation degradation, guiding maintenance decisions.

Evolution and Future Outlook

While IEEE C57.12.90-1993 has served as a foundational document, standards in the electrical industry evolve to incorporate technological advancements and emerging challenges. Recent revisions and related standards now include digital testing methods, real-time monitoring, and

environmental considerations.

Future developments may involve:

- Integration of smart testing devices
- Use of machine learning for data analysis
- Enhanced safety protocols for high-voltage testing
- Adaptation to renewable energy integration and grid modernization

Despite these advancements, the core principles established in IEEE C57.12.90-1993 continue to underpin best practices in electrical equipment testing.

Concluding Remarks

IEEE C57.12.90-1993 remains a cornerstone standard that exemplifies the importance of rigorous testing for electrical power equipment. Its comprehensive procedures, meticulous attention to testing conditions, and focus on safety and reliability have cemented its role in the industry. As electrical systems become more complex and demand higher standards of performance, adherence to such well-established guidelines ensures that equipment can withstand operational stresses, safeguard personnel, and provide dependable service for decades to come. For engineers, manufacturers, and utility operators, understanding and applying the principles of IEEE C57.12.90-1993 is essential to fostering a resilient and safe electrical infrastructure.

Question What is the purpose of the IEEE C57.12.90-1993 standard? The IEEE C57.12.90-1993 standard specifies testing procedures and requirements for liquid-immersed distribution, power, and regulating transformers to ensure their performance, reliability, and safety. **Answer** Does IEEE C57.12.90-1993 include testing methods for transformer insulation? Yes, the standard covers testing methods related to transformer insulation, including dielectric tests, insulation resistance, and other electrical performance assessments to verify transformer integrity. Is IEEE C57.12.90-1993 still applicable for modern transformer testing? While IEEE C57.12.90-1993 provides foundational testing procedures, newer standards and revisions have been issued. It's recommended to consult the latest standards for current testing practices, though this document remains relevant historically and for certain legacy applications. How does IEEE C57.12.90-1993 influence transformer quality control? The standard establishes standardized testing protocols that help manufacturers and inspectors verify transformer quality, ensuring consistency, safety, and compliance with industry benchmarks. Where can I access the full text of IEEE C57.12.90-1993? The full standard can be purchased or accessed through the IEEE Xplore digital library or authorized standards distributors. Some technical libraries or organizations may also provide access to the document.

Related keywords: IEEE C57.12.90-1993, electrical equipment testing, power transformer testing, dielectric properties, insulation testing, ANSI standards, electrical safety, transformer diagnostics, dielectric withstand test, electrical equipment standards, testing procedures

Read the full article online: [IEEE C57 12 90 1993](#)

HIGH VOLTAGE TEST TECHNIQUES

High Voltage Test Techniques are essential methods used in the electrical industry to ensure the integrity, safety, and performance of high voltage equipment and systems. These techniques are critical for verifying the insulation strength, detecting potential defects, and preventing catastrophic failures that could lead to power outages, equipment damage, or safety hazards. As electrical systems grow increasingly complex and demand higher reliability, understanding and implementing effective high voltage testing methods become more crucial than ever.

In this comprehensive guide, we will explore the various high voltage test techniques, their applications, procedures, and benefits. Whether you are an electrical engineer, technician, or maintenance professional, mastering these techniques will help you uphold safety standards and ensure the longevity of high voltage equipment.

Understanding High Voltage Testing

High voltage testing involves applying a voltage significantly higher than the normal operating voltage to electrical equipment or insulation systems to evaluate their dielectric strength. The primary goal is to identify weaknesses, flaws, or deterioration in insulation that could lead to failure during operation.

Why is High Voltage Testing Important?

- Ensures equipment safety and reliability
- Detects manufacturing defects or insulation deterioration
- Prevents unexpected outages and costly repairs
- Complies with industry standards and regulations
- Extends the lifespan of electrical assets

Types of High Voltage Tests

- Dielectric Withstand Test (Hi-Pot Test)
- Partial Discharge Test
- Surge Test
- Impulse Test
- Voltage Ratio Test
- Insulation Resistance Test

Each test serves specific purposes and is selected based on the type of equipment, application, and testing standards.

Common High Voltage Test Techniques

1. Dielectric Withstand Test (Hi-Pot Test)

The dielectric withstand test, commonly known as the Hi-Pot test, is one of the most widely used high voltage testing methods. It evaluates whether the insulation of a device can withstand a specified voltage without breakdown.

Procedure:

- Connect the test instrument to the equipment under test (EUT).
- Gradually increase the applied voltage to a predetermined test level, usually higher than the operational voltage.
 - Maintain the voltage for a specified duration (commonly 1 to 5 minutes).
 - Observe for any leakage current or flashover (arcing).
 - A passing result indicates the insulation can withstand the applied voltage; failure indicates defects.

Applications:

- Transformers
- Cables
- Switchgear
- Motors
- Insulation systems

Advantages:

- Simple and effective
- Quick testing process
- Detects weak insulation points

Safety Precautions:

- Use proper grounding and safety barriers
- Ensure personnel are at a safe distance
- Use insulated tools and equipment

2. Partial Discharge (PD) Testing

Partial discharge testing is a non-destructive technique that detects localized dielectric breakdowns within insulation systems. PD occurs when small electrical sparks happen within voids or inclusions in insulation, indicating potential weak spots.

Types of PD Tests:

- Offline PD testing
- Online PD testing

Procedure:

- Connect PD measurement equipment to the EUT.
- Apply the operating voltage or a test voltage.
- Use sensors (ultrasound, radio-frequency, or capacitive probes) to detect PD activity.
- Analyze PD patterns and magnitudes to assess insulation health.

Applications:

- Power transformers
- Cables
- GIS (Gas Insulated Switchgear)
- Rotating machines

Advantages:

- Early detection of insulation deterioration
- Non-destructive and allows continuous monitoring
- Provides insight into insulation condition over time

3. Surge Testing

Surge testing involves applying high-energy voltage surges to equipment to simulate lightning strikes or switching surges. It assesses the insulation's ability to withstand transient overvoltages.

Procedure:

- Use a surge generator to produce controlled high-voltage pulses.
- Apply surges to the equipment under test.
- Monitor for breakdown or flashover.

Applications:

- Power transformers
- Cables
- Insulation systems in switchgear

Benefits:

- Tests equipment under realistic transient conditions
- Detects weak spots vulnerable to surges

4. Impulse Testing

Impulse testing simulates lightning strikes by applying fast-rising voltage pulses to electrical apparatus, evaluating their ability to withstand such transient events.

Procedure:

- Utilize a specialized impulse generator.
- Apply standard lightning impulse waveforms (e.g., 1.2/50 μ s).
- Observe whether the insulation withstands the impulse without flashover or damage.

Applications:

- High-voltage equipment
- Insulator testing
- Transmission line components

Advantages:

- Ensures equipment resilience to lightning
- Standardized testing for compliance

5. Voltage Ratio Testing

Voltage ratio tests assess the turns ratio in transformers and other wound devices by applying a known voltage and measuring the output to verify correct operation.

Procedure:

- Apply a low-voltage test signal.
- Measure the output voltage ratio.
- Compare against the rated ratio specified by the manufacturer.

Applications:

- Transformers
- Instrument transformers

Benefits:

- Verifies correct winding connections
- Detects turns or winding faults

6. Insulation Resistance Testing (Megohmmeter Test)

While not strictly a high voltage test, insulation resistance testing provides preliminary information about insulation condition by applying a moderate voltage and measuring resistance.

Procedure:

- Connect a megohmmeter between conductors and ground.
- Apply test voltage (commonly 500V to 5kV).
- Record resistance readings; higher resistance indicates better insulation.

Applications:

- Routine maintenance
- Pre-test assessments before high voltage testing

Advantages:

- Quick and simple
- Cost-effective for routine checks

Standards and Safety Considerations

High voltage testing must adhere to international standards such as IEEE, IEC, and ANSI guidelines. Proper safety measures are critical to prevent accidents during testing.

Key Safety Measures:

- Use insulated test equipment and barriers
- Ensure the EUT is properly grounded
- Keep personnel at a safe distance or in protected zones
- Verify that the equipment is de-energized and discharged before testing
- Use warning signs and barriers to indicate testing in progress

Legal and Regulatory Compliance:

- Follow manufacturer instructions
- Maintain detailed testing records
- Conduct risk assessments prior to testing

Choosing the Right High Voltage Test Technique

Selecting the appropriate testing method depends on various factors:

- Type of equipment
- Inspection objectives
- Equipment's dielectric properties
- Environmental conditions
- Industry standards and regulations

A combination of tests often provides the most comprehensive assessment of insulation integrity.

Conclusion

High voltage test techniques are indispensable tools for ensuring the safety, reliability, and longevity of electrical systems and equipment. From dielectric withstand tests to partial discharge and surge testing, each method offers unique insights into the condition of insulation and overall system health. Proper application of these techniques, coupled with adherence to safety standards, helps prevent catastrophic failures, reduces maintenance costs, and ensures compliance with industry regulations.

Regular high voltage testing, along with ongoing monitoring, forms the backbone of a proactive maintenance strategy in high voltage power systems. By understanding and implementing these techniques effectively, electrical professionals can safeguard infrastructure, personnel, and the environment from the risks associated with high voltage operations.

Keywords for SEO Optimization:

High voltage test techniques, dielectric withstand test, Hi-Pot test, partial discharge testing, surge testing, impulse testing, insulation resistance, high voltage testing standards, electrical insulation testing, high voltage safety, transformer testing, cable testing, GIS testing, electrical system reliability

High Voltage Test Techniques: An In-Depth Review for Power Systems and Electrical Equipment

In the realm of electrical engineering and power systems, ensuring the integrity, safety, and performance of high voltage equipment is paramount. The high voltage test techniques are a suite of specialized procedures designed to evaluate the dielectric strength and operational integrity of electrical components and systems operating at elevated voltages. These tests are critical for preventing failures, ensuring compliance with standards, and maintaining system reliability. This article offers a comprehensive exploration of high voltage test techniques, delving into their principles, methodologies, applications, and recent advancements.

Introduction to High Voltage Testing

High voltage testing involves applying voltages significantly higher than normal operating levels to equipment to verify its dielectric strength—the capacity to withstand electric stress without breakdown. These tests are performed during manufacturing, commissioning, and periodic maintenance. They serve multiple purposes, such as detecting insulation defects, verifying manufacturing quality, and diagnosing aging or damage.

The importance of high voltage testing stems from the need to prevent catastrophic failures that can cause power outages, equipment damage, or safety hazards. The challenge lies in applying high voltages safely and accurately, which necessitates specialized techniques and equipment.

Fundamental Principles of High Voltage Testing

High voltage testing relies on fundamental electrical principles:

- Dielectric Strength: The maximum electric field a material can withstand without electrical breakdown.
- Partial Discharges (PD): Small electrical sparks that occur within voids or imperfections in insulation, detectable during testing.
- Leakage Current: The small current that flows through insulation under high voltage; increases indicate deteriorating insulation.

Effective testing aims to detect weaknesses or defects before they manifest as failures during operation. The tests must balance thoroughness with safety and equipment integrity, making the choice of technique critical.

Types of High Voltage Tests

High voltage testing can be broadly classified into two categories:

- Type Tests: Performed during the development or manufacturing phase to validate design.
- Acceptance Tests: Conducted before commissioning to ensure compliance with specifications.
- Periodic Tests: Regular inspections to monitor insulation condition over time.

Within these categories, various techniques are employed, each suited to specific equipment and testing objectives.

Common High Voltage Test Techniques

The principal high voltage test techniques include:

- High Voltage Withstand Test (Dielectric Test)
- Partial Discharge Measurement
- Polarization Index Test
- Tan Delta (Loss Factor) Test
- Corona Discharge Test
- Impulse Voltage Test
- Switching Surge Test

Each technique offers unique insights into insulation health and system reliability.

High Voltage Withstand Test (AC/DC Tests)

The most fundamental high voltage test involves applying a specified voltage?either alternating current (AC) or direct current (DC)?to a device or component for a defined duration.

Objectives:

- Confirm the insulation can withstand operational voltages.
- Detect gross defects such as cracks, voids, or contamination.

Methodology:

- A high voltage source is connected between the conductor and ground.
- Voltage is gradually increased to the test level.
- The voltage is maintained for a specified period (e.g., 1 minute to 15 minutes).
- Insulation resistance and leakage current are monitored.

Key Considerations:

- Test voltages are typically 1.5 to 2 times the rated voltage.
- Safety precautions are paramount to prevent accidents.
- The test may induce partial discharges, which should be monitored and interpreted.

Partial Discharge Measurement

Partial discharges (PD) are localized electrical discharges that do not completely bridge the insulation between conductors. Monitoring PD activity provides an early indication of insulation degradation.

Significance:

- Detects small defects before complete failure.
- Quantifies insulation quality.

Techniques:

- Pulse Current Method: Measures the current pulses associated with PD.
- Ultrasound Detection: Captures acoustic emissions from PD.
- Electromagnetic Method: Detects electromagnetic signals generated by PD.

Testing Procedure:

- Apply high voltage to the equipment.
- Use specialized sensors to detect PD activity.
- Analyze PD magnitude, phase, and pattern to assess insulation health.

Challenges:

- Differentiating between noise and genuine PD.
- Quantifying PD severity.

Polarization Index (PI) and Dielectric Absorption Ratio Tests

These tests evaluate the insulation's ability to store and absorb electrical energy, providing insight into moisture content and aging.

Procedure:

- Apply a DC voltage to the insulation.
- Measure the insulation resistance after 1 minute (R1) and after 10 minutes (R10).
- Calculate $PI = R10 / R1$.

Interpretation:

- A high PI (typically > 2) indicates healthy insulation.
- A low PI suggests moisture ingress or deterioration.

Tan Delta (Loss Factor) Testing

Tan delta testing measures the dissipation factor or dielectric loss angle, reflecting the insulation's energy loss.

Method:

- An AC voltage is applied.
- The phase difference between voltage and current is measured.
- The tan delta value indicates the level of dielectric losses.

Applications:

- Monitoring insulation aging.
- Detecting moisture or contamination.

Corona Discharge Test

Corona discharge occurs when high electric fields ionize the surrounding air around conductors or sharp edges.

Purpose:

- Detect corona activity which can degrade insulation.
- Assess the quality of high voltage equipment, such as insulators and busbars.

Technique:

- Visual inspection for corona glow.
- Acoustic or ultrasonic sensors for non-visible corona.
- Electrical measurements of corona-induced noise.

Impulse Voltage Testing

Impulse testing simulates lightning strikes and switching surges to verify equipment withstand capability.

Procedure:

- Apply high-voltage pulses with specified wave shape (e.g., standard lightning impulse wave).
- Incrementally increase the voltage until breakdown occurs or the maximum test level is reached.
- Record the flashover voltage.

Applications:

- Testing insulators, bushings, and surge arresters.
- Ensuring equipment durability against transient overvoltages.

Switching Surge and Surge Impulse Tests

These tests evaluate the ability of equipment to withstand switching transients and high-energy surges.

Method:

- Apply high energy surges mimicking switching operations.
- Measure the response and breakdown voltage.

Advancements in High Voltage Testing Technologies

Recent technological developments have enhanced high voltage testing methodologies:

- Non-Destructive Testing (NDT): Techniques like partial discharge and dielectric measurements allow for condition assessment without damaging equipment.
- Automated Test Systems: Integration of automation reduces human error and improves repeatability.
- Digital Signal Processing: Advanced algorithms improve PD detection and interpretation.
- Remote Monitoring: Wireless sensors enable real-time insulation health tracking.
- High-Speed Data Acquisition: Captures transient phenomena with high temporal resolution.

These innovations aim to increase the accuracy, safety, and efficiency of high voltage testing regimes.

Standards and Safety Considerations

High voltage testing must adhere to international standards such as IEC 60060, IEEE standards, and national regulations to ensure consistency, safety, and reliability.

Key safety measures include:

- Proper grounding and shielding.
- Use of insulated barriers and personal protective equipment.
- Clear warning signs and restricted access during testing.
- Emergency shutdown procedures.

Testing environments should be designed to contain potential arc flashes or equipment failures.

Conclusion

High voltage test techniques are vital tools for ensuring the safety and reliability of electrical power systems and equipment. From basic withstand tests to sophisticated partial discharge and dielectric loss measurements, each technique offers specific insights into the condition of insulation and dielectric materials. The ongoing evolution of testing technologies, driven by advancements in electronics and data analysis, continues to enhance the effectiveness and safety of high voltage testing practices.

Proper application of these techniques requires a thorough understanding of their principles, limitations, and safety protocols. As power systems grow more complex and the demand for higher efficiency and reliability increases, high voltage testing remains an indispensable component of electrical engineering and asset management.

By staying informed of current methodologies and emerging innovations, engineers and technicians can better safeguard electrical infrastructure, prevent failures, and ensure the continuous delivery of reliable power.

References:

- IEC 60060-1:2010, "High-voltage test techniques?Part 1: General definitions and test requirements."

- IEEE Std 4-2013, "IEEE Standard for Testing Insulation Resistance."
- Kuffel, E., Zaengl, W. S., & Kuffel, J. (2000). High Voltage Engineering: Fundamentals. Elsevier.
- IEEE Std 400-2012, "Guide for Partial Discharge Testing of Power Apparatus and Components."
- IEC 60270:2000, "Partial Discharges ? Measurement, Detection and Localization."

This comprehensive review highlights the critical role and diverse methodologies of high voltage test techniques, serving as a valuable resource for professionals engaged in electrical testing, maintenance, and research.

Question What are the primary purposes of high voltage testing in electrical equipment? High voltage testing is primarily used to verify the insulation integrity, detect defects, and ensure the safety and reliability of electrical equipment such as transformers, cables, and switchgear before commissioning or after maintenance. What are the common types of high voltage tests performed on electrical equipment? Common high voltage tests include dielectric withstand (power frequency withstand), impulse voltage testing, insulation resistance testing, and partial discharge testing, each serving to assess different aspects of insulation performance. How is a power frequency dielectric test conducted on a transformer? The power frequency dielectric test involves applying a high AC voltage at the equipment's rated frequency (typically 50 or 60 Hz) for a specified duration to ensure the insulation can withstand operational stresses without breakdown. What safety precautions should be taken during high voltage testing? Safety precautions include isolating the test area, using proper personal protective equipment (PPE), ensuring proper grounding, employing insulated tools, and following established safety protocols to prevent electric shock or equipment damage. How does partial discharge testing help in high voltage testing techniques? Partial discharge testing detects small electrical sparks within insulation that indicate defects or deterioration, enabling early identification of potential failures and ensuring long-term reliability of high voltage equipment. What is the significance of impulse voltage testing in high voltage testing techniques? Impulse voltage testing simulates lightning strikes or switching surges to evaluate the insulation's ability to withstand transient overvoltages, thereby assessing the robustness of electrical insulation under real-world fault conditions. What are the challenges associated with high voltage testing in the field versus laboratory conditions? Field testing presents challenges like environmental factors (humidity, temperature), accessibility issues, and safety concerns, whereas laboratory testing offers controlled conditions but may require more setup time and equipment mobility considerations. How do modern digital measurement techniques enhance high voltage testing procedures? Digital measurement techniques provide precise, real-time data, improved sensitivity for detecting partial discharges, automated data analysis, and enhanced safety features, making high voltage testing more accurate and efficient. What standards govern high voltage testing procedures globally? Standards such as IEC 60060, IEEE 400 series, and ANSI C37 provide guidelines for high voltage testing methods, ensuring consistency, safety, and reliability across different regions and types of electrical equipment.

Related keywords: high voltage testing, insulation resistance testing, dielectric withstand test, partial discharge testing, surge testing, high voltage equipment, testing procedures, electrical safety testing, insulation diagnostics, testing equipment

Read the full article online: [HIGH VOLTAGE TEST TECHNIQUES](#)

Ieee std 946

ieee std 946: A Comprehensive Guide to the Standard for Electrical Power System Equipment

Introduction to IEEE Std 946

ieee std 946 is a vital standard established by the Institute of Electrical and Electronics Engineers (IEEE) that focuses on the design, testing, and performance criteria for electrical power system equipment, particularly transformers and associated components. This standard plays a crucial role in ensuring the safety, reliability, and interoperability of electrical infrastructure across various industries. Whether you are an engineer, technician, or project manager, understanding the scope and application of IEEE Std 946 is essential for maintaining high-quality electrical systems.

Historical Background and Development

Origins of IEEE Std 946

IEEE Std 946 was developed to address the increasing complexity of electrical power systems and the need for standardized testing procedures. Its roots trace back to earlier standards and practices aimed at harmonizing transformer design and testing protocols.

Evolution Over Time

Over the years, IEEE Std 946 has undergone multiple revisions to incorporate technological advancements, improve safety measures, and align with international standards. This evolution ensures that the standard remains relevant in the context of modern electrical engineering applications.

Scope and Application of IEEE Std 946

Primary Focus Areas

IEEE Std 946 primarily deals with:

- Design specifications for electrical transformers
- Testing procedures to verify transformer performance
- Performance criteria for transformers and associated equipment
- Insulation and dielectric testing
- Temperature rise and load loss measurements

Applicable Equipment

The standard applies to various types of transformers, including:

- Distribution transformers
- Power transformers
- Specialized transformers for specific applications
- Auxiliary equipment related to transformers

Key Components and Definitions in IEEE Std 946

Transformers and Their Components

The standard provides detailed specifications for:

- Core materials and construction
- Windings and insulation
- Cooling mechanisms
- Protective devices

Important Terminology

Understanding specific terminology is vital. Some key terms include:

- **Impedance:** The opposition a transformer offers to alternating current
- **Losses:** Power dissipated as heat within the transformer
- **Overload capacity:** The maximum load a transformer can handle without damage
- **Dielectric strength:** The ability of insulating materials to withstand electric stress

Design and Testing Procedures as per IEEE Std 946

Design Guidelines

IEEE Std 946 offers comprehensive design criteria to ensure transformers meet safety and performance standards:

- Selection of appropriate core and winding materials
- Designing for thermal performance and cooling efficiency
- Ensuring insulation withstands voltage stresses
- Incorporating protective devices and features

Testing Protocols

Testing is a critical component of the standard, including:

- **Type Tests:** Confirming design parameters through tests like dielectric tests, temperature rise tests, and short-circuit tests
- **Routine Tests:** Performed on each transformer unit, such as insulation resistance, turns ratio, and power factor measurements
- **Acceptance Tests:** Ensuring the manufactured transformer complies with specified standards

Testing Procedures Include:

- Applied voltage tests to verify dielectric strength
- Load tests to assess temperature rise and efficiency
- Insulation resistance measurements
- Partial discharge tests to detect insulation defects

Performance and Safety Standards

Performance Criteria

IEEE Std 946 specifies acceptable ranges for:

- Voltage regulation
- Efficiency at various load conditions

- Temperature limits during operation
- Losses under load and no-load conditions

Safety Requirements

Safety is paramount in electrical equipment standards. The standard mandates:

- Proper grounding and insulation
- Protection against overcurrent and overloads
- Design features to prevent electrical faults
- Clear labeling and instructions for maintenance and operation

Benefits of Adhering to IEEE Std 946

Enhanced Reliability and Longevity

Following the guidelines ensures transformers operate efficiently over extended periods, reducing downtime and maintenance costs.

Standardized Quality Assurance

Uniform testing and design criteria facilitate consistent quality across manufacturing batches and installations.

Safety Assurance

Compliance with safety standards minimizes risks to personnel and equipment, preventing accidents and electrical hazards.

International Compatibility

As IEEE standards often align with IEC standards, adherence promotes compatibility in international projects and exports.

Implementation and Compliance Tips

Understanding the Standard

- Review the latest version of IEEE Std 946 thoroughly.

- Engage with professional engineering teams familiar with the standard.

Design and Manufacturing

- Incorporate IEEE Std 946 criteria early in the design phase.
- Use certified testing laboratories for compliance verification.

Maintenance and Inspection

- Regularly perform routine tests as specified.
- Keep detailed records of testing and maintenance activities.

Training and Education

- Provide ongoing training for personnel involved in installation, testing, and maintenance.
- Keep updated with revisions and amendments to the standard.

Conclusion

IEEE Std 946 is a cornerstone document that ensures the safe, efficient, and reliable operation of electrical transformers and related equipment. Its comprehensive approach to design, testing, and performance evaluation helps manufacturers, utilities, and engineers maintain high standards in electrical power systems. By adhering to IEEE Std 946, stakeholders can achieve optimal performance, enhance safety, and facilitate international compatibility, ultimately contributing to a more resilient and sustainable electrical infrastructure.

References and Further Reading

- IEEE Std 946-2002, "IEEE Standard for Power Transformer Impedance and Load Loss Testing"
- IEEE Standards Association Official Website
- Electrical Power System Design Textbooks and Guides
- International Electrotechnical Commission (IEC) standards related to transformers

IEEE STD 946: An In-Depth Examination of Its Development, Scope, and Impact on Power Systems

Introduction

In the realm of electrical engineering and power systems, standards play a pivotal role in ensuring safety, interoperability, and reliability. Among these, IEEE STD 946 stands as a critical document that delineates specifications for a specific aspect of electrical systems. While not as universally recognized as some broader standards like IEEE 802.3 or IEEE 1547, IEEE STD 946 holds particular significance within its niche, especially for professionals involved in high-voltage systems, insulation coordination, and power equipment design. This investigative article aims to thoroughly explore the origins, scope, technical provisions, evolution, and practical implications of IEEE STD 946, providing a comprehensive resource for engineers, researchers, and policymakers.

Historical Context and Development of IEEE STD 946

Origins and Need for the Standard

The genesis of IEEE STD 946 traces back to the growing complexity of power transmission and distribution systems in the mid-20th century. As voltage levels increased and new insulating materials emerged, the need for standardized testing and design criteria became apparent. Variability in design practices led to compatibility issues, equipment failures, and safety concerns.

The IEEE Standards Association responded by initiating efforts to establish uniform guidelines. The earliest versions of what would become IEEE STD 946 focused on defining test procedures and performance criteria for insulating materials and equipment, particularly in high-voltage applications.

Evolution Over Time

Since its initial publication, IEEE STD 946 has undergone multiple revisions, reflecting advances in material science, testing methodologies, and system requirements. Notable updates include:

- Incorporation of modern dielectric testing techniques.
- Clarification of test voltage levels and durations.
- Expansion of scope to include new insulation materials.
- Alignment with other relevant standards, such as IEEE Std 4 and IEEE Std 124.

Each revision aimed to enhance the reliability and safety of power equipment, accommodate technological innovations, and harmonize practices across different regions.

Scope and Purpose of IEEE STD 946

Primary Objectives

IEEE STD 946 provides standardized procedures and criteria for testing the dielectric strength and

insulation performance of electrical apparatus and components operating at high voltages. Its primary objectives are:

- To define test voltages and durations for various equipment types.
- To specify acceptable performance criteria post-testing.
- To promote consistency in testing practices across different laboratories and manufacturers.
- To facilitate safe and reliable operation of high-voltage equipment.

Applicability

The standard is applicable to a range of electrical equipment, including:

- Transformers
- Circuit breakers
- Insulators
- Switchgear
- Other high-voltage apparatus

It encompasses both factory testing and field testing scenarios, ensuring equipment meets specified dielectric performance standards before and after installation.

Technical Provisions and Key Requirements

Test Voltage Levels and Durations

At the core of IEEE STD 946 are detailed specifications for test voltages, which vary depending on equipment type, rated voltage, and insulation class. Key aspects include:

- Power Frequency Tests: Typically conducted at 50 or 60 Hz, with test voltages set at multiples of the equipment's rated voltage.
- Impulsive Tests: Designed to simulate lightning strikes or switching surges, employing standard waveforms such as 1.2/50 μ s.
- Partial Discharge Tests: To detect micro-voids or imperfections within insulation materials.

Test durations are specified to ensure sufficient stress without damaging the equipment, often ranging from several minutes to hours depending on the test type.

Acceptance Criteria

The standard defines criteria for passing or failing tests, including:

- No disruptive discharges or punctures during high-voltage testing.
- Insulation resistance remains within specified limits post-test.
- No significant degradation or damage observed upon visual inspection or electrical testing.

Testing Environment and Equipment

IEEE STD 946 stipulates conditions such as:

- Ambient temperature and humidity ranges.
- Calibration and accuracy requirements for test equipment.
- Proper grounding and shielding practices.

These ensure test results are consistent, reproducible, and indicative of actual performance.

Innovations and Technical Challenges Addressed

Material Diversity and Compatibility

As insulation materials diversified?from oil-filled insulators to solid dielectrics?the standard integrated testing protocols suitable for various materials. Addressing compatibility issues, the standard provides guidelines for testing composite and hybrid insulations.

High-Voltage Surge Testing

The increasing use of large-scale electrical infrastructure necessitated more rigorous surge testing procedures. IEEE STD 946 incorporated detailed impulsive testing criteria to replicate real-world lightning and switching events, enhancing equipment resilience.

Aging and Condition Monitoring

Recognizing the importance of assessing insulation degradation over time, recent revisions include provisions for partial discharge testing and other diagnostic techniques that can be integrated into routine maintenance protocols.

Impact on Industry and Practice

Enhancing Reliability and Safety

By standardizing testing procedures, IEEE STD 946 has contributed to:

- Reduction in equipment failures due to insulation breakdown.
- Improved safety margins for personnel and equipment.
- Facilitation of international trade and collaboration, given its recognized status.

Supporting Regulatory and Certification Processes

Many regional and national regulations reference IEEE standards, making compliance with IEEE STD 946 essential for manufacturers seeking certification or market approval.

Advancing Research and Development

The detailed technical criteria provided by IEEE STD 946 serve as benchmarks for developing new insulation materials and testing methodologies, fostering innovation in high-voltage engineering.

Challenges and Criticisms

Despite its strengths, IEEE STD 946 has faced several critiques:

- Complexity: The detailed procedures and specifications can be resource-intensive, posing challenges for smaller laboratories or emerging markets.
- Evolving Technology: Rapid advances in insulation materials and testing equipment sometimes outpace the standard's updates, leading to a lag in applicability.
- Regional Variations: Differences in environmental conditions and operational practices across regions may require localized adaptations, reducing universal applicability.

Efforts are ongoing within IEEE and industry stakeholders to address these issues through periodic revisions and supplementary guidelines.

Future Directions and Recommendations

Integration with Digital Technologies

Emerging diagnostic tools such as embedded sensors, machine learning algorithms, and remote monitoring present opportunities for IEEE STD 946 to incorporate more advanced testing and assessment protocols.

Climate and Environmental Considerations

Future revisions should consider the impacts of climate change, including increased humidity, pollution, and temperature extremes, on insulation performance.

Harmonization with Other Standards

Greater alignment with international standards (e.g., IEC standards) would facilitate global interoperability and compliance.

Emphasis on Sustainability

Incorporating sustainability criteria?such as eco-friendly materials and energy-efficient testing methods?will be essential as the industry moves toward greener practices.

Conclusion

IEEE STD 946 remains a cornerstone in the domain of high-voltage insulation testing, embodying decades of accumulated expertise and technological progress. Its meticulous specifications and procedures underpin the safety, reliability, and interoperability of electrical equipment worldwide. While challenges persist?particularly regarding technological evolution and regional adaptation?ongoing updates and industry engagement promise to sustain its relevance. For engineers, researchers, and regulators committed to advancing power system integrity, a thorough understanding and diligent application of IEEE STD 946 are indispensable.

References

- IEEE Standards Association. IEEE Std 946-2014: IEEE Guide for Testing Insulation of Power System Equipment. IEEE, 2014.
- IEEE Power Engineering Society. "Development and Evolution of High-Voltage Insulation Standards." Power Engineering Journal, vol. 29, no. 4, 2016.
- Smith, J. A., & Lee, K. W. (2019). "Advances in High-Voltage Insulation Testing: A Review of IEEE STD 946." Journal of Electrical Insulation, 45(2), 123-136.
- International Electrotechnical Commission. IEC 60060: High Voltage Test Techniques. IEC, 2010.

Note: This article is intended for informational and educational purposes, providing a comprehensive review of IEEE STD 946 within the context of electrical engineering standards.

QuestionAnswer What is IEEE Std 946 and what does it cover? IEEE Std 946 is a standard developed by the IEEE that specifies the requirements for the design, testing, and application of electrical power systems and equipment, particularly focusing on safety, performance, and reliability

in industrial and utility settings. How does IEEE Std 946 impact electrical safety protocols? IEEE Std 946 provides guidelines that enhance electrical safety by establishing standardized procedures for equipment installation, maintenance, and testing, thereby reducing hazards and ensuring safe operation of electrical systems. Is IEEE Std 946 applicable to all types of electrical installations? While primarily designed for industrial and utility electrical systems, IEEE Std 946 offers principles that can be adapted to various types of electrical installations, but its core focus remains on high-reliability environments. What are the key requirements outlined in IEEE Std 946? Key requirements include specifications for equipment design, grounding practices, insulation coordination, testing procedures, and maintenance protocols to ensure system reliability and safety. How does IEEE Std 946 relate to other IEEE standards in electrical engineering? IEEE Std 946 complements other standards by providing specific guidelines for certain aspects of electrical systems, such as safety and testing, and is often referenced alongside standards like IEEE 142 (Grounding) and IEEE 399 (Recommended Practice for Substation Design). Are there recent updates or revisions to IEEE Std 946? Yes, IEEE periodically reviews and updates its standards, including IEEE Std 946, to incorporate technological advancements and industry best practices; users should consult the latest version for current requirements. Where can I access the official IEEE Std 946 document? The official IEEE Std 946 document can be purchased or accessed through the IEEE Xplore digital library or authorized standards distributors on the IEEE website.

Related keywords: IEEE std 946, battery chargers, charger standard, IEEE standards, battery management, electric vehicle charging, power supply standards, electrical safety, charger design, standardization

Read the full article online: [ieee std 946](#)